

Product Certification Schedule

Schedule No: 017/004/270

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 6724:1997 & A3:2008 - 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation and low emission of smoke and corrosive gases when affected by fire.

Type of Cable: Tables 6, 8, 10 & 13- Two-core, three-core, four-core and five-core 600/1000V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Five-core. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: BRITCABLE (B) or (B) BRITCABLE or PRYSMIAN (B) or (B) PRYSMIAN

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2017

Signed for and on behalf of the British Approvals Service for Cables

Date 24/07/2014

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004