

Product Certification Schedule

Schedule No: 017/004/331

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 8436:2011 Electric Cables - Specification for 300/500V screened electric cables having low emission of smoke and corrosive gases when affected by fire, for use in walls, partitions and building voids - Multicore cables.

Type of Cable: Table 1 - Dimensions of cables

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive with uninsulated circuit protective conductor. Sheath - LTS3. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PRYSMIAN (B) or (B) PRYSMIAN

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004